

5.2 Precautions Against Fire

- (a) For the purpose of regulating the construction of buildings within the City of Penticton for precautions against fire all multiple residential occupancies over two stories in height and as defined in City of Penticton Zoning Bylaw No. 87-65 are designated as a Fire Limit Area pursuant to Section 734(1)(c) of the Municipal Act.
- (b) All multiple residential occupancies over two stories in height which require a fire alarm system pursuant to the British Columbia Building Code must also be equipped with an automatic sprinkler system on each floor.
- (c) All automatic sprinkler systems shall comply and be installed in accordance with the requirements of the National Fire Protection Association 13 and 13(R) and amendments thereto.